

Sizing and Startup Procedures for Cooling Systems

Research Report - 0109

26-October-2001

Armin Rudd

Abstract:

*High performance building envelopes deserve high performance comfort conditioning systems.
Especially for refrigerant based cooling systems, proper sizing and startup procedures are critical.*

Sizing and Startup Procedures for Cooling Systems

by

Armin Rudd

**Building Science Consortium
USDOE Building America Program**

for

**EEBA 2001 Excellence in Building Conference
Orlando, Florida
Friday, 26 October 2001, 10:05 - 11:30 am**



Building Science Corporation



Building America program

Production homebuilder partners:

Pulte, Centex, Del Webb, KB, Artistic, T&C, Sturbridge



October 2001



Building Science Consortium



Building Science Corporation



**High performance building envelopes
deserve high performance comfort
conditioning systems.**

**Especially for refrigerant based cooling
systems, proper sizing and startup
procedures are critical.**



October 2001



Building Science Consortium

Main Outline

- **Cooling system sizing procedures**
 - entire system and room-by-room flows
- **Duct and transfer air sizing procedures**
 - supply and return plenums
 - duct run-outs
 - transfer grilles and jump ducts
- **Refrigeration system set and startup procedures**
 - line-set install, connecting units, leak testing
 - evacuation, charging, checking charge and airflow



October 2001



Building Science Consortium

Cooling system sizing procedures: Entire system

- **Computerized ACCA Manual J approach**
 - **Elite Software - RHVAC**
 - **Wrightsoft - Right J**
 - **others**
- **need to handle especially carefully:**
 - **infiltration**
 - **ventilation**
 - **glazing, conversion of SHGC to SC** $SHGC = 0.86 SC$
 - **temperature swing multiplier**



October 2001



Building Science Consortium

Intermittent Ventilation Operation


- Sizing
 - intermittent flow equals constant flow reduced by low background infiltration amount when blower is not on, all divided by duty cycle fraction

$$\dot{Q}_{in} = \frac{(\dot{Q}_{co}) - \left(\frac{I}{60} V (1 - f)\right)}{f}$$



Central-fan-integrated supply ventilation

Outside air duct (filtered) connected to return filter grille pan



October 2001

Cooling system sizing procedures: Entire system (cont.)

- **Complete house model with front facing north, then rotate front of house to east, south, and west**
- **Size system to 100% of total load at worst orientation for subdivisions**
- **Choose equipment so that total cooling capacity matches the total cooling load at the outdoor design temperature**
 - **nominal ratings are for 95 F outdoor temperature**
 - **most unused latent capacity converts to sensible**



October 2001



Building Science Consortium

Cooling system sizing procedures: Room-by-room air flow

- For any given subdivision model, average the computed cfm's for each room across all four cardinal orientations
 - This gives maximum flexibility to balance flows from the middle rather than the extremes
- Choose supply registers that have multiple adjustable curved blades in front to direct air flow, and flat blades with a single-lever control in back to balance flow



October 2001



Building Science Consortium

Duct sizing

- Using the computerized ACCA Manual J approach, apply the following air velocity constraints to get appropriate duct sizing:
 - supply plenum: max 750 ft/min
 - supply run-outs: max 500 ft/min
 - return grille: max 350 ft/min (use 80% free area or actual)
 - return duct: max 500 ft/min

$$A = \frac{\dot{Q}}{v \cdot f}$$

where: A = area, ft²

\dot{Q} = volumetric flow, ft³/min

v = air speed, ft/min

f = free area fraction



October 2001



Building Science Consortium

Pulte Houston, Creek Bend, Manual J system sizing and duct sizing results

Plan 4244

		Orientation of Front of House									
		N	NE	E	SE	S	SW	W	NW	max	avg

		RHVAC program output								BSC Spec	
Heating Load (kBtu/h)		27.9									
Sensible Cooling Load (kBtu/h)		26.0		28.2		25.5		28.3			
Latent Cooling Load (kBtu/h)		3.7		3.7		3.7		3.7			
Total Cooling Load (kBtu/h)		29.8		32.0		29.2		32.0		32.0	30.8
Room Air Flow (cfm)											3.0 ton
Foyer		75		103		83		103		103	91
Dining		75		112		86		112		112	96
Kitchen		89		80		89		76		89	84
Breakfast		128		123		122		118		128	123
Great Room		165		215		143		215		215	185
Master Bedrm		138		178		121		178		178	154
Master Bath		39		22		39		27		39	32
Master Closet		13		13		13		13		13	13
Laundry		14		14		14		14		14	14
Game Rm		58		75		63		75		75	68
Bedrm 2		75		61		75		55		75	67
Hall, 2nd		21		21		21		21		21	21
Bath 2		35		49		29		49		49	41
Bedrm 3		77		57		77		63		77	69
Bedrm 4		75		56		75		62		75	67
Bedrm 4 Closet		10		10		10		10		10	10

Main supply trunk (minimum cross section): 18x16

Supply Duct Diameter (in)		RHVAC program output				BSC Spec
Foyer		1-6	1-7	1-6	1-7	1-7
Dining		1-6	1-7	1-6	1-7	1-7
Kitchen		1-6	1-6	1-6	1-6	1-6
Breakfast		1-7	1-7	1-7	1-7	1-7
Great Room		2-6	2-7	1-8	2-7	2-7
Master Bedrm		1-8	2-6	1-7	2-6	2-6
Master Bath		1-4	1-4	1-4	1-4	1-4
Master Closet		1-4	1-4	1-4	1-4	1-4
Laundry		1-4	1-4	1-4	1-4	1-4
Game Rm		1-5	1-6	1-5	1-6	1-6
Bedrm 2		1-6	1-5	1-6	1-5	1-6
Hall, 2nd		1-4	1-4	1-4	1-4	1-4
Bath 2		1-4	1-5	1-4	1-5	1-5
Bedrm 3		1-6	1-5	1-6	1-5	1-6
Bedrm 4		1-6	1-5	1-6	1-5	1-6
Bedrm 4 Closet		1-4	1-4	1-4	1-4	1-4

Transfer duct/grille sizing

- Calculate free area required to get proper transfer air flow to avoid more than 3 Pa pressurization

$$A = \frac{\dot{Q}}{1.07\sqrt{3}} = \frac{\dot{Q}}{1.853}$$

where: A = area in square inches
 \dot{Q} = air flow rate (ft³/min)

- For jump ducts, don't use less than 6" diameter, most master suites will need 10" to 12" diameter



October 2001



Building Science Consortium

Pulte Houston, Creek Bend, Transfer Area and Jump Duct sizing results

Plan 4244

		Orientation of Front of House							max	avg
		N	NE	E	SE	S	SW	W		

Air Transfer Free Area (in ²)

Foyer										
Dining										
Kitchen										
Breakfast										
Great Room										
Master Bedrm	87		99		77			102		102
Master Bath										91
Master Closet										
Laundry										
Game Rm	15		24		18			24		24
Bedrm 2	24		17		24			14		24
Hall, 2nd										20
Bath 2										
Bedrm 3	26		15		26			18		26
Bedrm 4	24		14		24			17		24
Bedrm 4 Closet										20

Jump Duct Diameter (in)

Foyer											
Dining											
Kitchen											
Breakfast											
Great Room											
Master Bedrm	10		11		10			11		11	10
Master Bath											
Master Closet											
Laundry											
Game Rm	4		6		5			6		6	6
Bedrm 2	6		5		6			4		6	6
Hall, 2nd											
Bath 2											
Bedrm 3	6		4		6			5		6	6
Bedrm 4	6		4		6			5		6	6
Bedrm 4 Closet											

**BSC
Spec**

Refrigeration system set and startup procedures

- 1 The refrigerant grade copper line set should not be left open to the atmosphere to collect contaminants. Cap it off at rough-in and fill with dry nitrogen to 125 psi.



October 2001



Building Science Consortium

Refrigeration system set and startup procedures

- 1 The line set should not be left open to the atmosphere to collect contaminants. Cap it off at rough-in and fill with dry nitrogen to 125 psi.
- 2 Make sure a filter/dryer is installed in the liquid line (bi-directional for heat pumps)
- 3 Using a silver/phosphorus/copper alloy, with between 5% and 15% silver, braze refrigerant line set to the indoor and outdoor units with nitrogen flowing inside tube
- 4 Check quality of joints visually, then check for leaks by pressurizing the system with between 125 and 150 psi



October 2001



Building Science Consortium

Refrigeration system set and startup procedures, cont.

- 5 Connect the manifold gauges, micron gauge, vacuum pump. Release the nitrogen charge and begin evacuation. A 2-stage pump is required.**
- 6 Evacuate to 300 microns or less. Isolate the vacuum pump and observe pressure change on the micron gauge. If the micron gauge reading drifts above 700, run the vacuum pump for another 15 minutes and repeat the process.**



October 2001



Building Science Consortium

BOILING TEMPERATURES OF WATER AT CONVERTED PRESSURES

Temperature in °F.	Inches of Mercury	Pounds Sq. In. (Pressure)	Microns*
212°	29.92	14.696	759,968
205°	25.00	12.279	635,000
194°	20.69	10.162	525,526
176°	13.98	6.866	355,092
158°	9.20	4.519	233,680
140°	5.88	2.888	149,352
122°	3.64	1.788	92,456
104°	2.17	1.066	55,118
86°	1.25	.614	35,560
80°	1.00	.491	25,400
76°	.90	.442	22,860
72°	.80	.393	20,320
69°	.70	.344	17,780
64°	.60	.295	15,240
59°	.50	.246	12,700
53°	.40	.196	10,160
45°	.30	.147	7,620
32°	.18	.088	4,572
21°	.10	.049	2,540
6°	.05	.0245	1,270
-24°	.01	.0049	254
-35°	.005	.00245	127
-60°	.001	.00049	25.4
-70°	.0005	.00024	12.7
-90°	.0001	.000049	2.54

*Remaining pressure in system in microns

1.000 inch = 25,400 microns = 2.540 CM = 25.40 MM

.100 inch = 2,540 microns = .254 CM = 2.54 MM

.039 inch = 1,000 microns = .100 CM = 1.00 MM

Refrigeration system set and startup procedures, cont.

- 7 **With the system in a vacuum, if the line set length is greater than the default length that the manufacturer pre-charged the condenser for, add refrigerant by weight to account for the actual line set according to the manufacturers specification for the tube diameter.**
 - **A digital refrigerant scale with resolution of at least 1/2 ounce is required**
- 8 **Release the refrigerant charge from the condenser into the line set and evaporator**



October 2001



Building Science Consortium

Refrigeration system set and startup procedures, cont.

- 9 If the line set length is less than the default length that the manufacturer pre-charged the condenser for, then remove refrigerant to account for the actual line set length according to the manufacturers specification.
 - A digital refrigerant scale with resolution of at least 1/2 ounce is required

- 10 Start the system and run for at least 15 minutes



October 2001



Building Science Consortium

Refrigeration system set and startup procedures, cont.

11 Check for proper sub-cooling for TXV (thermal expansion valve) systems.

The required sub-cooling is specified by the manufacturer and is usually 5 - 15 F. It is not dependent on inside or outside environmental conditions.

Adjust refrigerant charge as necessary.



October 2001



Building Science Consortium

Thermal expansion valve (TXV) refrigerant metering device



Refrigeration system set and startup procedures, cont.

- 12 If indoor and outdoor environmental conditions are favorable, check for proper superheat for capillary tube and accumulator/piston systems. Superheat is dependent on inside and outside environmental conditions.

If the target superheat is > 5 F, adjust refrigerant charge as necessary.



October 2001



Building Science Consortium

Table 1: Target Superheat (Suction Line Temperature - Evaporator Saturation Temperature)

		Return Air Wet-Bulb Temperature (°F)																										
		$(T_{return,wb})$																										
		50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76
Condenser Air Dry-Bulb Temperature (°F) $(T_{condenser,db})$	55	8.8	10.1	11.5	12.8	14.2	15.6	17.1	18.5	20.0	21.5	23.1	24.6	26.2	27.8	29.4	31.0	32.4	33.8	35.1	36.4	37.7	39.0	40.2	41.5	42.7	43.9	45.0
	56	8.6	9.9	11.2	12.6	14.0	15.4	16.8	18.2	19.7	21.2	22.7	24.2	25.7	27.3	28.9	30.5	31.8	33.2	34.6	35.9	37.2	38.5	39.7	41.0	42.2	43.4	44.6
	57	8.3	9.6	11.0	12.3	13.7	15.1	16.5	17.9	19.4	20.8	22.3	23.8	25.3	26.8	28.3	29.9	31.3	32.6	34.0	35.3	36.7	38.0	39.2	40.5	41.7	43.0	44.2
	58	7.9	9.3	10.6	12.0	13.4	14.8	16.2	17.6	19.0	20.4	21.9	23.3	24.8	26.3	27.8	29.3	30.7	32.1	33.5	34.8	36.1	37.5	38.7	40.0	41.3	42.5	43.7
	59	7.5	8.9	10.2	11.6	13.0	14.4	15.8	17.2	18.6	20.0	21.4	22.9	24.3	25.7	27.2	28.7	30.1	31.5	32.9	34.3	35.6	36.9	38.3	39.5	40.8	42.1	43.3
	60	7.0	8.4	9.8	11.2	12.6	14.0	15.4	16.8	18.2	19.6	21.0	22.4	23.8	25.2	26.6	28.1	29.6	31.0	32.4	33.7	35.1	36.4	37.8	39.1	40.4	41.6	42.9
	61	6.5	7.9	9.3	10.7	12.1	13.5	14.9	16.3	17.7	19.1	20.5	21.9	23.3	24.7	26.1	27.5	29.0	30.4	31.8	33.2	34.6	35.9	37.3	38.6	39.9	41.2	42.4
	62	6.0	7.4	8.8	10.2	11.7	13.1	14.5	15.9	17.3	18.7	20.1	21.4	22.8	24.2	25.5	27.0	28.4	29.9	31.3	32.7	34.1	35.4	36.8	38.1	39.4	40.7	42.0
	63	5.3	6.8	8.3	9.7	11.1	12.6	14.0	15.4	16.8	18.2	19.6	20.9	22.3	23.6	25.0	26.4	27.8	29.3	30.7	32.2	33.6	34.9	36.3	37.7	39.0	40.3	41.6
	64	-	6.1	7.6	9.1	10.6	12.0	13.5	14.9	16.3	17.7	19.0	20.4	21.7	23.1	24.4	25.8	27.3	28.7	30.2	31.6	33.0	34.4	35.8	37.2	38.5	39.9	41.2
	65	-	5.4	7.0	8.5	10.0	11.5	12.9	14.3	15.8	17.1	18.5	19.9	21.2	22.5	23.8	25.2	26.7	28.2	29.7	31.1	32.5	33.9	35.3	36.7	38.1	39.4	40.8
	66	-	-	6.3	7.8	9.3	10.8	12.3	13.8	15.2	16.6	18.0	19.3	20.7	22.0	23.2	24.6	26.1	27.6	29.1	30.6	32.0	33.4	34.9	36.3	37.6	39.0	40.4
	67	-	-	5.5	7.1	8.7	10.2	11.7	13.2	14.6	16.0	17.4	18.8	20.1	21.4	22.7	24.1	25.6	27.1	28.6	30.1	31.5	33.0	34.4	35.8	37.2	38.6	39.9
	68	-	-	-	6.3	8.0	9.5	11.1	12.6	14.0	15.5	16.8	18.2	19.5	20.8	22.1	23.5	25.0	26.5	28.0	29.5	31.0	32.5	33.9	35.3	36.8	38.1	39.5
	69	-	-	-	5.5	7.2	8.8	10.4	11.9	13.4	14.8	16.3	17.6	19.0	20.3	21.5	22.9	24.4	26.0	27.5	29.0	30.5	32.0	33.4	34.9	36.3	37.7	39.1
	70	-	-	-	-	6.4	8.1	9.7	11.2	12.7	14.2	15.7	17.0	18.4	19.7	20.9	22.3	23.9	25.4	27.0	28.5	30.0	31.5	33.0	34.4	35.9	37.3	38.7
	71	-	-	-	-	5.6	7.3	8.9	10.5	12.1	13.6	15.0	16.4	17.8	19.1	20.3	21.7	23.3	24.9	26.4	28.0	29.5	31.0	32.5	34.0	35.4	36.9	38.3
	72	-	-	-	-	-	6.4	8.1	9.8	11.4	12.9	14.4	15.8	17.2	18.5	19.7	21.2	22.8	24.3	25.9	27.4	29.0	30.5	32.0	33.5	35.0	36.5	37.9
	73	-	-	-	-	-	5.6	7.3	9.0	10.7	12.2	13.7	15.2	16.6	17.9	19.2	20.6	22.2	23.8	25.4	26.9	28.5	30.0	31.5	33.1	34.6	36.0	37.5
	74	-	-	-	-	-	-	6.5	8.2	9.9	11.5	13.1	14.5	15.9	17.3	18.6	20.0	21.6	23.2	24.8	26.4	28.0	29.5	31.1	32.6	34.1	35.6	37.1
75	-	-	-	-	-	-	5.6	7.4	9.2	10.8	12.4	13.9	15.3	16.7	18.0	19.4	21.1	22.7	24.3	25.9	27.5	29.1	30.6	32.2	33.7	35.2	36.7	
76	-	-	-	-	-	-	-	6.6	8.4	10.1	11.7	13.2	14.7	16.1	17.4	18.9	20.5	22.1	23.8	25.4	27.0	28.6	30.1	31.7	33.3	34.8	36.3	
77	-	-	-	-	-	-	-	5.7	7.5	9.3	11.0	12.5	14.0	15.4	16.8	18.3	20.0	21.6	23.2	24.9	26.5	28.1	29.7	31.3	32.8	34.4	36.0	
78	-	-	-	-	-	-	-	-	6.7	8.5	10.2	11.8	13.4	14.8	16.2	17.7	19.4	21.1	22.7	24.4	26.0	27.6	29.2	30.8	32.4	34.0	35.6	
79	-	-	-	-	-	-	-	-	5.9	7.7	9.5	11.1	12.7	14.2	15.6	17.1	18.8	20.5	22.2	23.8	25.5	27.1	28.8	30.4	32.0	33.6	35.2	
80	-	-	-	-	-	-	-	-	-	6.9	8.7	10.4	12.0	13.5	15.0	16.6	18.3	20.0	21.7	23.3	25.0	26.7	28.3	29.9	31.6	33.2	34.8	
81	-	-	-	-	-	-	-	-	-	6.0	7.9	9.7	11.3	12.9	14.3	16.0	17.7	19.4	21.1	22.8	24.5	26.2	27.9	29.5	31.2	32.8	34.4	
82	-	-	-	-	-	-	-	-	-	5.2	7.1	8.9	10.6	12.2	13.7	15.4	17.2	18.9	20.6	22.3	24.0	25.7	27.4	29.1	30.7	32.4	34.0	
83	-	-	-	-	-	-	-	-	-	-	6.3	8.2	9.9	11.6	13.1	14.9	16.6	18.4	20.1	21.8	23.5	25.2	26.9	28.6	30.3	32.0	33.7	
84	-	-	-	-	-	-	-	-	-	-	5.5	7.4	9.2	10.9	12.5	14.3	16.1	17.8	19.6	21.3	23.0	24.8	26.5	28.2	29.9	31.6	33.3	
85	-	-	-	-	-	-	-	-	-	-	6.6	8.5	10.3	11.9	13.7	15.5	17.3	19.0	20.8	22.6	24.3	26.0	27.8	29.5	31.2	32.9		
86	-	-	-	-	-	-	-	-	-	-	5.8	7.8	9.6	11.3	13.2	15.0	16.7	18.5	20.3	22.1	23.8	25.6	27.3	29.1	30.8	32.6		
87	-	-	-	-	-	-	-	-	-	-	5.0	7.0	8.9	10.6	12.6	14.4	16.2	18.0	19.8	21.6	23.4	25.1	26.9	28.7	30.4	32.2		
88	-	-	-	-	-	-	-	-	-	-	-	6.3	8.2	10.0	12.0	13.9	15.7	17.5	19.3	21.1	22.9	24.7	26.5	28.3	30.1	31.8		
89	-	-	-	-	-	-	-	-	-	-	-	5.5	7.5	9.4	11.5	13.3	15.1	17.0	18.8	20.6	22.4	24.3	26.1	27.9	29.7	31.5		
90	-	-	-	-	-	-	-	-	-	-	-	-	6.8	8.8	10.9	12.8	14.6	16.5	18.3	20.1	22.0	23.8	25.6	27.5	29.3	31.1		

Refrigeration system set and startup procedures, cont.

- 13 Check for proper temperature drop across the evaporator coil (varies with return air dry bulb and wet bulb temperature, usually 15 - 25 F).

Check static pressures in the supply and return plenums (max 125 Pa differential across blower).

Correct for any airflow problems/restrictions as necessary.



October 2001



Building Science Consortium

Refrigeration system set and startup procedures, cont.

According to the best engineering data available, the performance loss using a TXV metering device is about 5% if the refrigerant charge is off by plus or minus 20%.

The performance loss using a fixed metering device (capillary tube or accumulator) is about 15% to 20% if the refrigerant charge is off by plus or minus 20%.

Therefore, TXV systems are best, however, by following the installation procedure listed above, the refrigerant charge should be within about 5% every time, limiting the performance loss to about 5%.



October 2001



Building Science Consortium

Additional Resources

- “Just the facts,” Thermal Engineering Company, Toledo, OH
- “Fundamentals of dehydrating a refrigerant system,” Robinair Manufacturing Corp., Montpelier, OH
- “Influence of the expansion device on air-conditioner system performance characteristics under a range of charging conditions,” Farzad and O’Neal, ASHRAE Transactions 1993, V. 99, Pt. 1.
- “Residential cooling load calculation methods analysis,” Proctor Engineering Group.
- “Soldering and brazing copper tube,” Copper Development Association Inc.
- “Three refrigerant states,” Wheeler, Contracting Business, Dec 1989.
- “Split system space cooling refrigerant charge and air flow measurement,” California Energy Commission, Contractor’s Report, #P 400-01-014, <http://www.energy.ca.gov/reports>.



October 2001



Building Science Consortium

About this Report

This was first presented at the 2001 EEBA Conference in Orlando, Florida and was produced in cooperation with the US Department of Energy's Building America Program.

About the Author

Armin Rudd is a principal engineer at Building Science Corporation in Westford, Massachusetts. More information about Armin Rudd can be found at www.buildingscienceconsulting.com.

Direct all correspondence to: Building Science Corporation, 30 Forest Street, Somerville, MA 02143.

Limits of Liability and Disclaimer of Warranty:

Building Science documents are intended for professionals. The author and the publisher of this article have used their best efforts to provide accurate and authoritative information in regard to the subject matter covered. The author and publisher make no warranty of any kind, expressed or implied, with regard to the information contained in this article.

The information presented in this article must be used with care by professionals who understand the implications of what they are doing. If professional advice or other expert assistance is required, the services of a competent professional shall be sought. The author and publisher shall not be liable in the event of incidental or consequential damages in connection with, or arising from, the use of the information contained within this Building Science document.