

Transfer Grille Sizing

Research Report - 0005

2000

Armin Rudd

Abstract:

Sizing information excerpted from "BA-0006: Discussion of the Use of Transfer Grilles to Facilitate Air Flow in Central Return Systems."

Building Science Corporation

Architecture and Building Science



Transfer Grille Sizing Table

- Goal is to prevent pressurization of individual bedrooms when door is closed
- Maximum pressurization of 3 Pa (0.012 WIC) is specified
- Transfer grille size is based on supply flow to room
- At master bedroom suite (or any other multi-room suite), supply flows must be totalled, and transfer grille sized based on that total

Given:

Door width: 32 inch
 Door undercut: 0.5 inch
 Transfer grille width: 10, 12, or 14 inches
 Net free area: 0.75 fraction of total grille area

Find: How high does the return air transfer grille have to be to meet the 3 Pa criteria?

Room supply air flow (CFM)	Net free area required (in ²)	Area required after door undercut (in ²)	Transfer grille height required for listed width in inches			Jump Duct Diameter Required (in)
			10	12	14	
			(in)	(in)	(in)	
50	27.0	11.0	1.5	1.2	1.0	3.7
75	40.5	24.5	3.3	2.7	2.3	5.6
100	54.0	38.0	5.1	4.2	3.6	7.0
125	67.4	51.4	6.9	5.7	4.9	8.1
150	80.9	64.9	8.7	7.2	6.2	9.1
175	94.4	78.4	10.5	8.7	7.5	10.0
200	107.9	91.9	12.3	10.2	8.8	10.8
225	121.4	105.4	14.1	11.7	10.0	11.6
250	134.9	118.9	15.9	13.2	11.3	12.3
275	148.4	132.4	17.7	14.7	12.6	13.0
300	161.9	145.9	19.4	16.2	13.9	13.6
325	175.4	159.4	21.2	17.7	15.2	14.2
350	188.9	172.9	23.0	19.2	16.5	14.8

Based on $Q = 1.07 \times A \times \Delta P^{0.5}$ for square edged orifice flow

where: Q = room supply flow (CFM)
 1.07 = constant, including unit conversions
 A = free area (in²)
 ΔP = pressure difference between room and central area (Pa)



Typical Free Area Measurements of Return Air Grilles

- Ameri-Flow Return Air Grilles
- Data from Grainger Catalog (2001)

Nominal		Overall size		Free Area (in ²)
Width	Height	Width	Height	
10	6	11.5	7.5	51
12	6	13.5	7.5	61
12	12	13.5	13.5	121
14	6	15.5	7.5	71
14	14	15.5	15.5	163
20	20	21.5	21.5	336
30	6	31.5	7.5	153



About the Author

Armin Rudd is a principal engineer at Building Science Corporation in Westford, Massachusetts. More information about Armin Rudd can be found at www.buildingscienceconsulting.com.

Direct all correspondence to: Building Science Corporation, 30 Forest Street, Somerville, MA 02143.

Limits of Liability and Disclaimer of Warranty:

Building Science documents are intended for professionals. The author and the publisher of this article have used their best efforts to provide accurate and authoritative information in regard to the subject matter covered. The author and publisher make no warranty of any kind, expressed or implied, with regard to the information contained in this article.

The information presented in this article must be used with care by professionals who understand the implications of what they are doing. If professional advice or other expert assistance is required, the services of a competent professional shall be sought. The author and publisher shall not be liable in the event of incidental or consequential damages in connection with, or arising from, the use of the information contained within this Building Science document.